

Summary of Requirements for 40 CFR Part 63 Subpart JJJJJ:
NESHAP for Area Sources: Industrial, Commercial, and Institutional Boilers

Summary of Requirements for 40 CFR Part 63 Subpart JJJJJ:
NESHAP for Area Sources: Industrial, Commercial, and Institutional Boilers

Row	Subcategory	Task 1 Submit Initial Notifications		Task 2 Comply with Work Practice Standards (§63.11201)			Task 3 Meet Emission Limits		Task 4	Task 5		
		Submit Initial Notification of Applicability ¹	Submit Initial Notification of Compliance Status ²	Minimize Startup/Shutdown per Mfg. Procedures	Conduct Performance Tune-up ^{2,3}	Conduct Energy Assessment	For this pollutant	Initial Compliance	Continuous Compliance	Record	Submit Other Notifications and Reports	
ALL Gas-Fired Boilers (ALL sizes, new or existing)												
1	Gas	No	No	No	No	No	None		None	None		
Existing - Small (< 10MMBtu/hr)												
2	All fuel types other than gas (biomass, coal, oil)	Yes, submit by 9/17/2011. §63.11225(a)(2)	Yes, submit by 7/19/2012. 63.11225(a)(4)	No	Yes, Biennial. First tune-up completed by 3/21/2012. Subsequent tune-ups should be completed no later than 25 months after the previous tune-up. §63.11223(b)	No	None	None	Biennial compliance certification report (§63.11225(b)). Prepare first report by 3/1/2015. Subsequent reports prepared by March 1 of every other year.	Notification to combust solid waste (§63.11225(f)). Submit 30 days prior to combusting solid waste.		
									Records of dates and procedures for each boiler tune up (§63.11225(c)(2)(i) and §63.11223(b)(6))			
									Records of fuel use and non-waste determinations (§63.11225(c)(2)(ii)). You should begin keeping fuel records on 5/20/2011.	Notification of fuel or subcategory switching (§63.11225(g)). Submit 30 days prior to switching fuels.		
									Records of all submitted notifications (§63.11225(c)(1))			
Existing - Large (≥ 10MMBtu/hr)												
3	Biomass	Yes, submit by 9/17/2011. §63.11225(a)(2)	Yes, submit by 7/19/2012 for tune-up. Re-submit by 7/19/2014 for energy assessment. 63.11225(a)(4)	No	Yes, Biennial. First tune-up completed by 3/21/2012. Subsequent tune-ups should be completed no later than 25 months after the previous tune-up. §63.11223(b)	Yes, by 3/21/2014. (Table 2)	None	None	Biennial compliance certification report (§63.11225(b)). Prepare first report by 3/1/2015. Subsequent reports prepared by March 1 of every other year.	Notification to combust solid waste (§63.11225(f)). Submit 30 days prior to combusting solid waste.		
									Records of dates and procedures for each boiler tune up (§63.11225(c)(2)(i) and §63.11223(b)(6)).			
									Records of fuel use and non-waste determinations (§63.11225(c)(2)(ii)). You should begin keeping fuel records on 5/20/2011.	Notification of fuel or subcategory switching (§63.11225(g)). Submit 30 days prior to switching fuels.		
									Records of all submitted notifications (§63.11225(c)(1))			
4	Oil	Yes, submit by 9/17/2011. §63.11225(a)(2)	Yes, submit by 7/19/2012 for tune-up. Re-submit by 7/19/2014 for energy assessment. 63.11225(a)(4)	No	Yes, Biennial. First tune-up completed by 3/21/2012. Subsequent tune-ups should be completed no later than 25 months after the previous tune-up. §63.11223(b)	Yes, by 3/21/2014. (Table 2)	None	None	Biennial compliance certification report (§63.11225(b)). Prepare first report by 3/1/2015. Subsequent reports prepared by March 1 of every other year.	Notification to combust solid waste (§63.11225(f)). Submit 30 days prior to combusting solid waste.		
									Records of dates and procedures for each boiler tune up (§63.11225(c)(2)(i) and §63.11223(b)(6)).			
									Records of fuel use and non-waste determinations (§63.11225(c)(2)(ii)). You should begin keeping fuel records on 5/20/2011.	Notification of fuel or subcategory switching (§63.11225(g)). Submit 30 days prior to switching fuels.		
									Records of all submitted notifications (§63.11225(c)(1))			
Existing - Large (≥ 10MMBtu/hr)												
5	Coal	Yes, submit by 9/17/2011. §63.11225(a)(2)	Yes. Submit within 60 days of conducting performance test for mercury and CO, or no later than 7/19/2014, whichever is earlier. Submit by 7/19/2014 for energy assessment. (§63.11225(a)(4)). Include a statement on Startup and Shutdown according to manufacturer specifications	Yes, beginning 3/21/2014. §63.11223(c) §63.11214(d)	No	Yes, by 3/21/2014. (Table 2)	Hg	Conduct performance (stack) test (§63.11212, Table 4, and 63.7(c), (d), (f)) by 3/21/2014.	Triennial stack test (§63.11220(a) and §63.11212), no more than 37 months after previous test.	Records of fuel use and non-waste determinations (§63.11225(c)(2)(ii)). You should begin keeping fuel records in March 2013.	Notification to combust solid waste (§63.11225(f)). Submit 30 days prior to combusting solid waste. Notification of fuel or subcategory switching (§63.11225(g)). Submit 30 days prior to switching fuels.	
									OR			
									Conduct fuel analysis (63.11213, Table 5 and 63.11211(c)) by 3/21/2014.	If Hg limit compliance demonstrated based on fuel analysis, conduct fuel analysis for each fuel type burned monthly (§63.11213 and §63.11220(e))	Energy Assessment Report (§63.11214(c)) should be completed by 3/21/2014.	Deviations from emission limits and corrective actions taken during reporting period (§63.11225(b)(3)). ⁵ Submit by March 15 of each calendar year where deviations occurred.
									Establish operating limits (§63.11222, Table 6 and 63.11211(b)) by 3/21/2014.	Operate monitoring systems and collect data at all required intervals (§63.11221 and Table 7) including fuel mercury content and relevant control device monitoring systems.	For sources demonstrating compliance with fuel analysis, records of all calculation and supporting documentation to demonstrate compliance with emission limits (§63.11225(c)(3))	
									Conduct CMS performance evaluations (§63.11224) ⁶ by 3/21/2014.		Records of type and amount of all fuels burned in each boiler during reporting period (§63.11222(a))	Notification of affirmative defense within two business days of malfunction (§63.11226(b))
									Conduct performance (stack) test (§63.11212 and Table 4) by 3/21/2014.		Records of the each boiler or control device malfunction occurrence and duration and actions taken to minimize emissions during malfunctions (§63.11225(c)(4)-(5))	
Establish operating limits (§63.11222, Table 6 and 63.11211(b)) by 3/21/2014.	Triennial stack test (§63.11212)	Records of monitoring data and maintenance (§63.11225(c)(6))	Root cause analysis report of the malfunction within 45 days of the occurrence of the malfunction									

Summary of Requirements for 40 CFR Part 63 Subpart JJJJJ:
NESHAP for Area Sources: Industrial, Commercial, and Institutional Boilers

Summary of Requirements for 40 CFR Part 63 Subpart JJJJJ:
NESHAP for Area Sources: Industrial, Commercial, and Institutional Boilers

Row	Subcategory	Task 1 Submit Initial Notifications		Task 2 Comply with Work Practice Standards (§63.11201)			Task 3 Meet Emission Limits			Task 4	Task 5
		Submit Initial Notification of Applicability ¹	Submit Initial Notification of Compliance Status ²	Minimize Startup/Shutdown per Mfg. Procedures	Conduct Performance Tune-up ^{2,3}	Conduct Energy Assessment	For this pollutant	Initial Compliance	Continuous Compliance	Record	Submit Other Notifications and Reports
			(§63.11223(c))				CO	Install oxygen monitor (§63.11224(a)) by 3/21/2014. Establish operating limits (§63.11222 and 63.11211(b)) by 3/21/2014. Conduct CMS performance evaluations (§63.11224) by 3/21/2014.	Operate monitoring systems and collect data at all required intervals (§63.11221 and Table 7).	Site-specific test plan shall be prepared before each stack test (§63.11212(a), §63.7(c)) ⁶ Annual compliance certification report (§63.11225(b)) ^{5,6} Prepare first report by 3/1/2015. Thereafter, by March 1 of each calendar year. Site-specific monitoring plan shall be prepared 60 days before CMS performance evaluation for each CMS (§63.11205(c)(1) through (3)) ⁶	Within 45 days of the exceedance of the standard (§63.11226(b)) Submit results of mercury test data to EPA's Central Data Exchange using the ERT < http://www.epa.gov/ttnchie1/ert/ert_tool.html > (§63.11225(e)) within 60 days of completing each performance test.
New - Small (< 10MMBtu/hr)							New - Small (< 10MMBtu/hr)				
6	All fuel types other than gas (biomass, coal, oil)	Yes, submit by 9/17/2011 or within 120 days after startup, whichever is later. §63.11225(a)(2)	Yes, submit by 9/17/2011 or within 120 days of startup, whichever is later. §63.11225(a)(4)	No	Yes, Biennial. First tune-up completed by 5/20/2011 or upon start-up of the boiler, whichever is later. Subsequent tune-ups should be completed no later than 25 months after the previous tune-up. §63.11223(b)	No		None		Biennial compliance certification report (§63.11225(b)). Prepare by 3/1/2012 or on March 1 of the year immediately following start-up of the boiler. Records of dates and procedures for each boiler tune up (§63.11225(c)(2)(i) and §63.11223(b)(6)) Records of fuel use and non-waste determinations (§63.11225(c)(2)(ii)). You should begin keeping fuel records upon start-up of the boiler. Records of all submitted notifications (§63.11225(c)(1))	Notification to combust solid waste (§63.11225(f)). Submit 30 days prior to combusting solid waste. Notification of fuel or subcategory switching (§63.11225(g)). Submit 30 days prior to switching fuels.
New - Large (≥ 10MMBtu/hr)							New - Large (≥ 10MMBtu/hr)				
7	Coal	Yes, submit by 9/17/2011 or within 120 days after startup, whichever is later. §63.11225(a)(2)	Yes, submit by 9/17/2011, or within 120 days of startup, whichever is later. The notification must be submitted within 60 days of completing the performance test. (§63.11225(a)(4)). Include a statement on Startup and Shutdown according to manufacturer specifications (§63.11223(c))	Yes, beginning 5/20/2011 or upon start-up of the boiler. §63.11223(c) §63.11214(d)	No	No	Hg	Conduct performance (stack) test (§63.11212, Table 4, and 63.7(c), (d), (f)) by 5/20/2011 or upon startup. OR Conduct fuel analysis (§63.11213, Table 5 and §63.11211(c)) by 5/20/2011 or upon startup. Establish operating limits (§63.11222, Table 6 and §63.11211(b)) by 5/20/2011 or upon startup. Conduct CMS performance evaluations (§63.11224) ⁴ by 5/20/2011 or upon startup.	Triennial stack test (§63.11220(a) and §63.11212), no more than 37 months after previous test. If Hg limit compliance demonstrated based on fuel analysis, conduct fuel analysis for each fuel type burned monthly (§63.11213 and §63.11220(e)) Operate monitoring systems and collect data at all required intervals (§63.11221 and Table 7) including fuel mercury content and relevant control device monitoring systems.	Records of fuel use and non-waste determinations (§63.11225(c)(2)(ii)). You should begin keeping fuel records upon start-up of the boiler. Records of all submitted notifications (§63.11225(c)(1)) For sources demonstrating compliance with fuel analysis, records of all calculation and supporting documentation to demonstrate compliance with emission limits (§63.11225(c)(3)) Records of type and amount of all fuels burned in each boiler during reporting period (§63.11222(a))	Notification to combust solid waste (§63.11225(f)). Submit 30 days prior to combusting solid waste. Notification of fuel or subcategory switching (§63.11225(g)). Submit 30 days prior to switching fuels. Deviations from emission limits and corrective actions taken during reporting period (§63.11225(b)(3)). ⁵ Submit by March 15 of each calendar year where deviations occurred.
							CO	Conduct performance (stack) test (§63.11212 and Table 4) by 5/20/2011 or upon startup. Establish operating limits (§63.11222, Table 6 and §63.11211(b)) by 5/20/2011 or upon startup. Install oxygen monitor (§63.11224(a)) by 5/20/2011 or upon startup. Establish operating limits (§63.11222 and 63.11211(b)) by 5/20/2011 or upon startup. Conduct CMS performance evaluations (§63.11224) by 5/20/2011 or upon startup.	Triennial stack test (§63.11212), no more than 37 months after previous test. Operate monitoring systems and collect data at all required intervals (§63.11221 and Table 7).	Records of the each boiler or control device malfunction occurrence and duration and actions taken to minimize emissions during malfunctions (§63.11225(c)(4)-(5)) Records of monitoring data and maintenance (§63.11225(c)(6)) Annual compliance certification report (§63.11225(b)) ^{5,6} Prepare first report by 3/1/2012 (or on March 1 of the calendar year immediately following start-up of the boiler). Subsequent reports prepared by March 1 of the next calendar year.	Notification of affirmative defense within two business days of malfunction (§63.11226(b)) Root cause analysis report of the malfunction within 45 days of the exceedance of the standard (§63.11226(b))
							PM	Conduct performance (stack) test (§63.11212 and Table 4) by 5/20/2011 or upon startup. Establish operating limits (§63.11222 and 63.11211(b)) by 5/20/2011 or upon startup. Conduct CMS performance evaluations (§63.11224) by 5/20/2011 or upon startup.	Triennial stack test (§63.11212), no more than 37 months after previous test. Monitor parameters and collect data (§63.11221)	Site-specific monitoring plan shall be prepared 60 days before CMS performance evaluation for each CMS (§63.11205(c)(1) through (3)) ⁶ Site-specific test plan shall be prepared before each stack test (§63.11212(a), §63.7(c)) ⁶	Submit results of mercury, CO and PM test data to EPA's Central Data Exchange using the ERT < http://www.epa.gov/ttnchie1/ert/ert_tool.html > (§63.11225(e)) within 60 days of completing each performance test.
New - Large (≥ 10MMBtu/hr)							New - Large (≥ 10MMBtu/hr)				
			The notification for compliance with the PM emission limits must be submitted within 60 days of completing the					Conduct performance (stack) test (§63.11212 and Table 4) by 5/20/2011 or upon startup.	Triennial stack test (§63.11212) no more than 37 months after previous test.	Annual compliance certification report (§63.11225(b)) ^{5,6} Prepare first report by 3/1/2012 (or on March 1 of the calendar year immediately following start-up of the boiler). Subsequent reports prepared by March 1 of the next calendar year. Records of dates and procedures for each boiler tune up (§63.11225(c)(2)(i) and §63.11223(b)(6))	Notification to combust solid waste (§63.11225(f)). Submit 30 days prior to combusting solid waste. Notification of fuel or subcategory switching (§63.11225(g)). Submit 30 days prior to switching fuels.

Summary of Requirements for 40 CFR Part 63 Subpart JJJJJJ:
NESHAP for Area Sources: Industrial, Commercial, and Institutional Boilers

Summary of Requirements for 40 CFR Part 63 Subpart JJJJJJ:
NESHAP for Area Sources: Industrial, Commercial, and Institutional Boilers

Row	Subcategory	Task 1 Submit Initial Notifications		Task 2 Comply with Work Practice Standards (§63.11201)			Task 3 Meet Emission Limits		Task 4	Task 5	
		Submit Initial Notification of Applicability ¹	Submit Initial Notification of Compliance Status ²	Minimize Startup/Shutdown per Mfg. Procedures	Conduct Performance Tune-up ^{2,3}	Conduct Energy Assessment	For this pollutant	Initial Compliance	Continuous Compliance	Record	Submit Other Notifications and Reports
8	Biomass	Yes, submit by 9/17/2011 or within 120 days after startup, whichever is later. §63.11225(a)(2)	performance test and you can resubmit a notification for the tune-up (§63.11225(a)(4)). If this notification does not include the tune-up, you can re-submit a notification for the tune-up by 9/17/2011, or within 120 days of startup, whichever is later. Include a statement on Startup and Shutdown according to manufacturer specifications (§63.11223(c))	Yes, beginning 5/20/2011 or upon start-up of the boiler. §63.11223(c) §63.11214(d)	Yes, Biennial. First tune-up completed by 5/20/2011 or upon start-up of the boiler, whichever is later. Subsequent tune-ups should be completed no later than 25 months after the previous tune-up. §63.11223(b)	No	PM	Establish operating limits (§63.11222 and 63.11211(b)) by 5/20/2011 or upon startup. Conduct CMS performance evaluations (§63.11224) by 5/20/2011 or upon startup.	Monitor parameters and collect data §63.11221	Records of fuel use and non-waste determinations (§63.11225(c)(2)(iii)). You should begin keeping fuel records upon start-up of the boiler. Records of all submitted notifications (§63.11225(c)(1)) Records of the each boiler or control device malfunction occurrence and duration and actions taken to minimize emissions during malfunctions (§63.11225(c)(4)-(5)) Records of monitoring data and maintenance (§63.11225(c)(6)) Site-specific monitoring plan shall be prepared 60 days before CMS performance evaluation for each CMS (§63.11205(c)(1) through (3)) ⁶ Site-specific test plan shall be prepared before each stack test (§63.11212(a), §63.7(c)) ⁶	Deviations from emission limits and corrective actions taken during reporting period (§63.11225(b)(3)). ⁵ Notification of affirmative defense within two business days of malfunction (§63.11226(b)) Root cause analysis report of the malfunction within 45 days of the exceedance of the standard (§63.11226(b)) Submit results of PM test data to EPA's Central Data Exchange using the ERT < http://www.epa.gov/ttnchie1/ert/ert_tool.html > (§63.11225(e)) within 60 days of completing each performance test.
New - Large (≥ 10MMBtu/hr)											
9	Oil	Yes, submit by 9/17/2011 or within 120 days after startup, whichever is later. §63.11225(a)(2)	The notification for compliance with the PM emission limits must be submitted within 60 days of completing the performance test and you can resubmit a notification for the tune-up (§63.11225(a)(4)). If this notification does not include the tune-up, you can re-submit a notification for the tune-up by 9/17/2011, or within 120 days of startup, whichever is later. Include a statement on Startup and Shutdown according to manufacturer specifications (§63.11223(c))	Yes, beginning 5/20/2011 or upon start-up of the boiler. §63.11223(c) §63.11214(d)	Yes, Biennial. First tune-up completed by 5/20/2011 or upon start-up of the boiler, whichever is later. Subsequent tune-ups should be completed no later than 25 months after the previous tune-up. §63.11223(b)	No	PM	Conduct performance (stack) test (§63.11212 and Table 4) by 5/20/2011 or upon startup. Establish operating limits (§63.11222 and 63.11211(b)) by 5/20/2011 or upon startup. Conduct CMS performance evaluations (§63.11224) by 5/20/2011 or upon startup.	Triennial stack test (§63.11212) no more than 37 months after previous test.	Annual compliance certification report (§63.11225(b)) ^{5,6} Prepare first report by 3/1/2012 (or on March 1 of the calendar year immediately following start-up of the boiler). Subsequent reports prepared by March 1 of the next calendar year. Records of dates and procedures for each boiler tune up (§63.11225(c)(2)(i) and §63.11223(b)(6)) Records of fuel use and non-waste determinations (§63.11225(c)(2)(iii)). You should begin keeping fuel records upon start-up of the boiler. Records of all submitted notifications (§63.11225(c)(1)) Records of the each boiler or control device malfunction occurrence and duration and actions taken to minimize emissions during malfunctions (§63.11225(c)(4)-(5)) Records of monitoring data and maintenance (§63.11225(c)(6)) Site-specific monitoring plan shall be prepared 60 days before CMS performance evaluation for each CMS (§63.11205(c)(1) through (3)) ⁶ Site-specific test plan shall be prepared before each stack test (§63.11212(a), §63.7(c)) ⁶	Notification to combust solid waste (§63.11225(f)). Submit 30 days prior to combusting solid waste. Notification of fuel or subcategory switching (§63.11225(g)). Submit 30 days prior to switching fuels. Deviations from emission limits and corrective actions taken during reporting period (§63.11225(b)(3)). ⁵ Notification of affirmative defense within two business days of malfunction (§63.11226(b)) Root cause analysis report of the malfunction within 45 days of the exceedance of the standard (§63.11226(b)) Submit results of PM test data to EPA's Central Data Exchange using the ERT < http://www.epa.gov/ttnchie1/ert/ert_tool.html > (§63.11225(e)) within 60 days of completing each performance test.

1 Initial Notification of Applicability. National Emissions Standards for Hazardous Air Pollutants: Industrial, Commercial, and Institutional Boilers Area Sources (40 CFR Part 63 Subpart JJJJJJ). March 31, 2011. Available online at: <<http://www.epa.gov/airtoxics/boiler/boilerpg.html>>
2 Initial Notification of Compliance Status for Boilers Subject to Tune-ups - Area Sources. National Emissions Standards for Hazardous Air Pollutants: Industrial, Commercial, and Institutional Boilers Area Sources (40 CFR Part 63 Subpart JJJJJJ). April 21, 2011. Available online at: <<http://www.epa.gov/airtoxics/boiler/boilerpg.html>>
3 Tune-up Guidance and Example Recordkeeping Form-Area Sources. National Emissions Standards for Hazardous Air Pollutants: Industrial, Commercial, and Institutional Boilers Area Sources (40 CFR Part 63 Subpart JJJJJJ). April 21, 2011. Available online at: <<http://www.epa.gov/airtoxics/boiler/boilerpg.html>>
4 Only for source that petitions for an alternative monitoring parameters under §63.8. Mercury CEMS is not required under this rule.
5 If deviations occur during the reporting period, you must submit the entire contents of the annual compliance certification report (§63.11225(b) by March 15 of the calendar year immediately following the reporting period.
6 These items must be prepared and kept on-site unless your delegated authority requests these items to be submitted.